

HTE# 07-500-17786R

Harnett County Department of Public Health

24795

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Pine Grove Dev. Corp PROPERTY LOCATION: NC 24
 SUBDIVISION NATURE'S CROSS ROADS LOT # 48
 NEW REPAIR EXPANSION 4
 Type of Structure: MH - 76 x 26 @ BR
 Proposed Wastewater System Type: 25% Reduction system
 Projected Daily Flow: 300480 GPD
 Number of bedrooms: 04 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 50 feet Permit valid for: Five years
 No expiration
 Permit conditions: STUBOUT Plumbing shallow At ground level or higher
where shown meet or better maintain all setbacks

Authorized State Agent: Ja WADU Date: 05-29-08 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Pine Grove Dev. Corp PROPERTY LOCATION: NC 24
 SUBDIVISION NATURE'S CROSS LOT # 48
 Facility Type: MH 76 x 26 - @ BR New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction system (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable 25% Reduction system (Repair))

Installation Requirements/Conditions

Septic Tank Size <u>1000</u> gallons	Number of trenches <u>1</u>	Exact length of each trench <u>300</u> feet	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size _____ gallons	Trenches shall be installed on contour at a	Maximum Trench Depth of: <u>18</u> inches	Soil Cover: <u>6</u> inches
	(Trench bottoms shall be level to +/- 1/4"	in all directions)	(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: _____ inches below pipe
 _____ inches above pipe
 _____ inches total

Conditions: _____

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Ja WADU Date: 05-29-08
 Construction Authorization Expiration Date: 05-29-2013

HTE# 07-500-17786 R

Permit # 24795

Harnett County Department of Public Health Site Sketch

ISSUED TO: Pine Grove Dev. Corp. PROPERTY LOCATOR: NC 24
SUBDIVISION: NATURE'S CROSS ROAD LOT # 48


Authorized State Agent: J. W. [Signature] Date: 05-29-08

Meet on site

Maintain all setbacks

Install 300' of 25% Reduction system at 18"

STUD out Plumbing shallow at ground level or higher where shown



124 Sweet Bay