

November 7, 2007

James Jeffrey Howard  
Benhaven School Rd  
Sanford, NC 27330

**Re: Status of Improvement Permit Application #07-5-18706**

Dear Mr. Howard,

On November 6, 2007, an attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Property lines/corners not marked or labeled
- 2. House corners not marked or labeled
- 3. Directions not clear to property
- 4. Property needs brush or vegetation removed
- 5. Backhoe pits required
- 6. Other – See below the 2 options available to you

**Option #1 Have someone design a low pressure pipe (LPP) system for your site. The designer will need to meet me at your site so that I can show them the area suitable for a low pressure pipe (LPP) system. You need to know that an LPP system requires a yearly contract with a certified operator.**

**Option #2 Since you own the 21.02 acre tract that surrounds your 2.46 acre tract, you can get a private soil consultant to find a suitable area on your adjoining property for either an off site septic easement or to add a suitable area to your existing 2.46 acre tract.**

Your application will be put on hold until the selected items above have been addressed.

You may **call me at 910-893-7547 between 8 – 9:00** to discuss your revisions to the application and we will then reschedule your property for evaluation. Please submit any changes to your application to Central Permitting.

Sincerely,



Joe West, R. S.  
Environmental Health Specialist  
Harnett County Department of Public Health

JW/ss

Copy: Central Permitting