
ADDRESS . . : 52 LEONARD DR SUBDIV:
CONTRACTOR : TAR HEEL MODULAR HOMES PHONE : (910) 424-8330
OWNER . . : RAY HUGH MICHAEL & SHELIA #25 PHONE : (910) 893-2246
PARCEL . . : 10-0559- - -0046- -32-
APPL NUMBER: 08-50019451 CP MANUFACTURED HOME RA 20R CRITERIA
DIRECTIONS : STOCKYARD ROAD EST II LOT #25. 401S 1
MILE, RIGHT ON STOCKYARD ROAD GO 1/2
MILE, LEFT ON RAY BYRD RD, LEFT ON
LEONARD DRIVE, 3RD LOT ON RIGHT.
T/S: 02/19/2008 10:21 AM VBROWN ----

STRUCTURE: 000 000 28X80 DWMH
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	5/12/08	TI <i>DA JB</i>	R*MOBILE HOME FOUND./ M. WALL VRU #: 001606934

----- COMMENTS AND NOTES -----

ADDRESS . . : 52 LEONARD DR SUBDIV:
CONTRACTOR : TAR HEEL MODULAR HOMES PHONE : (910) 424-8330
OWNER . . . : RAY HUGH MICHAEL & SHELIA #25 PHONE : (910) 893-2246
PARCEL . . . : 10-0559- - -0046- -32-
APPL NUMBER: 08-50019451 CP MANUFACTURED HOME RA 20R CRITERIA
DIRECTIONS : STOCKYARD ROAD EST II LOT #25. 401S 1
MILE, RIGHT ON STOCKYARD ROAD GO 1/2
MILE, LEFT ON RAY BYRD RD, LEFT ON
LEONARD DRIVE, 3RD LOT ON RIGHT.
T/S: 02/19/2008 10:21 AM VBROWN ----

STRUCTURE: 000 000 28X80 DWMH
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	5/12/08 5/12/08	JH DA	R*MOBILE HOME FOUND./ M. WALL VRU #: 001606934 1) House not ready for roughin inspection, no drain lines install or tested. 2) No setup manual. Need to check setup. 3) Tie down straps loose. 4) Permit card needs to be on site 5) No electircal work on house.
H824 01	5/20/08 5/20/08	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001614791
T501 02	5/29/08	TI JH AP	R*MOBILE HOME FOUND./ M. WALL VRU #: 001616192

----- COMMENTS AND NOTES -----

ADDRESS : 52 LEONARD DR SUBDIV:
CONTRACTOR : TAR HEEL MODULAR HOMES PHONE : (910) 424-8330
OWNER : RAY HUGH MICHAEL & SHELIA #25 PHONE : (910) 893-2246
PARCEL : 10-0559- - -0046- -32-
APPL NUMBER: 08-50019451 CP MANUFACTURED HOME RA 20R CRITERIA

DIRECTIONS : STOCKYARD ROAD EST II LOT #25. 401S 1
MILE, RIGHT ON STOCKYARD ROAD GO 1/2
MILE, LEFT ON RAY BYRD RD, LEFT ON
LEONARD DRIVE, 3RD LOT ON RIGHT.
T/S: 02/19/2008 10:21 AM VBROWN ----

STRUCTURE: 000 000 28X80 DWMH
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	5/12/08 5/12/08	JH DA	R*MOBILE HOME FOUND./ M. WALL VRU #: 001606934 1)House not ready for roughin inspection, no drain lines install or tested. 2)No setup manual.Need to check setup. 3)Tie down straps loose. 4)Permit card needs to be on site 5)No electircal work on house.
H824 01	5/20/08 5/20/08	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001614791
T501 02	5/29/08 5/29/08	JH AP	R*MOBILE HOME FOUND./ M. WALL VRU #: 001616192
Z818 02	6/09/08 <u>6/9/08</u>	TI <u>AP/AD</u>	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 001622232

----- COMMENTS AND NOTES -----

ADDRESS : 52 LEONARD DR SUBDIV:
 CONTRACTOR : TAR HEEL MODULAR HOMES PHONE : (910) 424-8330
 OWNER : RAY HUGH MICHAEL & SHELIA #25 PHONE : (910) 893-2246
 PARCEL : 10-0559- - -0046- -32-
 APPL NUMBER: 08-50019451 CP MANUFACTURED HOME RA 20R CRITERIA
 DIRECTIONS : STOCKYARD ROAD EST II LOT #25. 401S 1
 MILE, RIGHT ON STOCKYARD ROAD GO 1/2
 MILE, LEFT ON RAY BYRD RD, LEFT ON
 LEONARD DRIVE, 3RD LOT ON RIGHT.
 T/S: 02/19/2008 10:21 AM VBROWN ----
 PREMISE # 52597141 *****

STRUCTURE: 000 000 28X80 DWMH
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	5/12/08 5/12/08	JH DA	R*MOBILE HOME FOUND./ M. WALL VRU #: 001606934 1)House not ready for roughin inspection, no drain lines install or tested. 2)No setup manual.Need to check setup. 3)Tie down straps loose. 4)Permit card needs to be on site 5)No electircal work on house.
H824 01	5/20/08 5/20/08	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001614791
T501 02	5/29/08 5/29/08	JH AP	R*MOBILE HOME FOUND./ M. WALL VRU #: 001616192
A814 01	6/09/08 6/09/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001622208 52 LEONARD DR LOT 25 52 LEONARD DR LOT 25
Z818 02	6/09/08 6/09/08	AD AP	✓ PZ*ZONING INSPECTION TIME: 17:00 VRU #: 001622232
T503 01	6/10/08	TI	R*MOBILE HOME INSPECTION VRU #: 001622539
Z818 01	6/10/08 6/06/08	TI CA	PZ*ZONING INSPECTION VRU #: 001622216

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFO Mobile Home

Conditional Use Permit No.: _____

Type of Construction: ✓

Building Permit No.: _____

Owner of Building: Michael Ray (June McDonald)

Electrical Permit No.: _____

Building Address: 52 Leonard St

Insulation Permit No.: _____

Zoning District: _____

Plumbing Permit No.: _____

Zoning Permit No.: _____

Mech. Permit No.: _____

Envir. C.O. No.: _____

Date: 6-10-08

James T. Hill
Building Official

08 50191151
Zoning Official