

DO NOT REMOVE!

Harnett County Inspection Department
102 East Front Street • P.O. Box 65
Lillington, NC 27546
Phone: (910) 893-7527 • Fax: (910) 893-2793

Job Name: _____ Date: 3-26-9

Address: 720 Pine Oak

Lot No.: _____ Permit No.: 19502

(Check Box for Violation)

- | | | | | | | | |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg. | <input type="checkbox"/> Elec. | <input type="checkbox"/> Plumb. | <input type="checkbox"/> Mech. | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other | |

Violations Found: _____

- 1) extend fill Pipe 8" higher
- 2) Fill with water and stop all Leaks under house
- 3) Rear door requires a 3'x3' Landing at top with railing on Landing and steps

Code Enforcement Official _____ Date: _____
Signature Mike Reovic

It is unlawful for any sub contractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation.

ADDRESS : 720 PINE OAK ST SUBDIV: SWEETBRIAR ESTATES
 CONTRACTOR : DAVIS MOBILE HOME MOVING INC PHONE : (910) 425-9524
 OWNER : GREY BETTY PHONE :
 PARCEL : 09-9563-01- -0158- -03-
 APPL NUMBER: 08-50019502 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
 DIRECTIONS : SWEETBRIAR EST LOT #70
 87 27W 24 TURN RIGHT OFF ABOVE FOOD
 LION HIT MARKS RD ABOUT 3 1/2 TO 2ND
 PINE OAKS TO THE END, LOT #70 SWEET
 BRIAR EST.
 T/S: 02/26/2008 09:26 AM VBROWN -----

LAND NOTES : LXMN 6/02/05 LOTS 114-115 COMBINED TO MAKE PARCEL 1

STRUCTURE: 000 000 14X70 2BDR SWMH
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 2.00 MOBILE HOME YEAR : 1000.00
 PROPOSED USE : SWMH SEPTIC - EXISTING? : EXISTING

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	3/26/09 3/26/09	MR DA	R*MOBILE HOME FOUND./ M. WALL VRU #: 001747641 extend drain fill pipe 89" higher and fill with water. repair all leaks under house reagr door will require a landing with railing and proper steops at final inspection
T501 02	3/30/09 3/30/09	TR AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001748847 CALL CUSTOMER WITH RESULTS IF PASSED OR FAILED AFTER INSP 910 424 2922 IF NO ONE ANSWERS LEAVE MESSAGE AFTER BEEP. CUSTOMER NAME BETTY GREY. T/S: 03/27/2009 09:57 AM VBROWN -----

FS

COMMENTS AND NOTES

ADDRESS : 720 PINE OAK ST
CONTRACTOR : DAVIS MOBILE HOME MOVING INC
OWNER : GREY BETTY
PARCEL : 09-9563-01- -0158- -03-
APPL NUMBER: 08-50019502 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : SWEETBRIAR EST LOT #70
87 27W 24 TURN RIGHT OFF ABOVE FOOD
LION HIT MARKS RD ABOUT 3 1/2 TO 2ND
PINE OAKS TO THE END, LOT #70 SWEET
BRIAR EST.
T/S: 02/26/2008 09:26 AM VBROWN ----
LAND NOTES : LXMN 6/02/05 LOTS 114-115 COMBINED TO MAKE PARCEL 1

SUBDIV: SWEETBRIAR ESTATES
PHONE : (910) 425-9524
PHONE :

*VRU-6373
Flood Barriers*

STRUCTURE: 000 000 14X70 2BDR SWMH
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 2.00 MOBILE HOME YEAR : 1000.00
PROPOSED USE : SWMH SEPTIC - EXISTING? : EXISTING

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	3/26/09 3/26/09	MR DA	R*MOBILE HOME FOUND./ M. WALL VRU #: 001747641 extend drain fill pipe 89" higher and fill with water. repair all leaks under house reagr door will require a landing with railing and proper steops at final inspection
T501 02	3/30/09 3/30/09	FS AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001748847 CALL CUSTOMER WITH RESULTS IF PASSED OR FAILED AFTER INSP 910 424 2922 IF NO ONE ANSWERS LEAVE MESSAGE AFTER BEEP. CUSTOMER NAME BETTY GREY. T/S: 03/27/2009 09:57 AM VBROWN -----
A814 01	4/07/09	TI	ADDRESS CONFIRMATION VRU #: 001751759
Z818 01	4/07/09 <u>4/7/09</u>	TI <u>R.B. / AP Cond.</u>	PZ*ZONING INSPECTION VRU #: 001751767

COMMENTS AND NOTES

*Building Inspector. Verify Property Owner has completed
The Landscaping around towing device.*

ADDRESS : 720 PINE OAK ST
CONTRACTOR : DAVIS MOBILE HOME MOVING INC
OWNER : GREY BETTY
PARCEL : 09-9563-01- -0158- -03-
APPL NUMBER: 08-50019502 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : SWEETBRIAR EST LOT #70
87 27W 24 TURN RIGHT OFF ABOVE FOOD
LION HIT MARKS RD ABOUT 3 1/2 TO 2ND
PINE OAKS TO THE END, LOT #70 SWEET
BRIAR EST.
T/S: 02/26/2008 09:26 AM VBROWN ----
LAND NOTES : LXMN 6/02/05 LOTS 114-115 COMBINED TO MAKE PARCEL 1

SUBDIV: SWEETBRIAR ESTATES
PHONE : (910) 425-9524
PHONE :

450
0.795

STRUCTURE: 000 000 14X70 2BDR SWMH
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 2.00 MOBILE HOME YEAR : 1000.00
PROPOSED USE : SWMH SEPTIC - EXISTING? : EXISTING

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	3/26/09 3/26/09	MR DA	R*MOBILE HOME FOUND./ M. WALL VRU #: 001747641 extend drain fill pipe 89" higher and fill with water. repair all leaks under house reagr door will require a landing with railing and proper steops at final inspection
T501 02	3/30/09 3/30/09	FS AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001748847 CALL CUSTOMER WITH RESULTS IF PASSED OR FAILED AFTER INSP 910 424 2922 IF NO ONE ANSWERS LEAVE MESSAGE AFTER BEEP. CUSTOMER NAME BETTY GREY. T/S: 03/27/2009 09:57 AM VBROWN -----
A814 01	4/07/09 4/07/09	TI AP	ADDRESS CONFIRMATION VRU #: 001751759 ✓ 720 PINE OAK LOT 70
Z818 01	4/07/09 4/07/09	RB AE	PZ*ZONING INSPECTION VRU #: 001751767 MIKE, PLEASE MAKE SURE THAT THE TONGUE OR TOWING DEVICE IS COMPLETELY CONCEALED WHEN YOU GO OUT ON THE FINAL INSPECTION. THEY WERE IN THE PROCESS OF DOING SO WHEN RANDY WENT OUT AND HE NEEDS YOU TO MAKE SURE IT IS COMPLETE. THANKS, NANCY ***** ***** *****
T507 01	4/08/09 4-8-09	TI AP	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 001752823

Handwritten signature and date: 4-8-09 AP

COMMENTS AND NOTES

Handwritten signature: FS

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: V

Owner: BETTY GREG

911 Address: 724 FIRE DR

State: NC Zip Code: _____

Date: 4-8-9

[Signature]
Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

MFG. Home: 8-5-19502