

April 14, 2008

Harnett County Government Complex  
307 Cornelius Harnett Boulevard  
Lillington, NC 27546

Shirley Browning  
2412 W. Brinkley Drive  
Spring Lake, NC 28390

ph: 910-893-7547  
fax: 910-893-9371

Re: Existing Tank Inspection HTE #08-5-19792

Dear Ms. Browning,

The Harnett County Department of Public Health, Environmental Health Division on April 10, 2008, evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting the placement of a 12 x 70 mobile home, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

- 15A NCAC 18A.1950 a(16) Any swimming pool must be 15' from any part of septic system.
- 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area.
- 15A NCAC 18A.1950 (10) – Any building to be 5' from drain line.

**Your proposed home location is on top of your septic system, and therefore cannot be approved. Your option is to move the proposed home site off of septic area - (marked by my red flags) and submit a new plot plan to Central Permitting. You will need to uncover the outlet end of tank as (marked by white flag). Please note that septic system is designed for one home only.**

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

Joe West, R.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

JW/sgs