

HTE#08-5-199442

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME CELESTINO ZEREDA PHONE # 893-3453

ADDRESS 100 RAYBIRD RD LILLINGTON NC 27546

NAME OF MOBILE HOME PARK OR S/D _____

NAME OF OWNER (IF DIFFERENT) MIKE RAY

ADDRESS OF OWNER (IF DIFFERENT) 3417 SPRING HILL CH. RD LILLINGTON

PROPERTY LOCATION: STATE ROAD NAME AND # 2035 STOCKYARD RD

PURPOSE OF INSPECTION: CHANGE OF HOUSE LOCATION


The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM


Signature of Environmental Health Specialist

12/11/08
Date