
ADDRESS . . : 76 RAY BYRD RD SUBDIV: STOCKYARD ESTATES
CONTRACTOR : RAVEN ROCK MOBILE HOME MOVER PHONE : (919) 775-3600
OWNER . . . : RAY HUGH MICHAEL & SHEILA #32 PHONE : (910) 893-2246
PARCEL . . . : 10-0559- - -0046- -39-
APPL NUMBER: 08-50019944 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : STOCKYARD RD #32-401S RT ON STOCKYARD
RD RT ON RAY BYRD 4TH LOT ON RT.JD

STRUCTURE: 000 000 28X70 3BR NO DECKS

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 MOBILE HOME YEAR : 1.00
PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

| TYP/SQ | REQUESTED | INSP | DESCRIPTION |
|---------|-----------|--------|--|
| | COMPLETED | RESULT | RESULTS/COMMENTS |
| T501 01 | 9/25/08 | TI | R*MOBILE HOME FOUND./ M. WALL VRU #: 001681584 |

OA JH Drain Line Has PVC & ABS mixed

COMMENTS AND NOTES

ADDRESS : 76 RAY BYRD RD SUBDIV: STOCKYARD ESTATES
 CONTRACTOR : RAVEN ROCK MOBILE HOME MOVER PHONE : (919) 775-3600
 OWNER : RAY HUGH MICHAEL & SHEILA #32 PHONE : (910) 893-2246
 PARCEL : 10-0559- - -0046- -39-
 APPL NUMBER: 08-50019944 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
 DIRECTIONS : STOCKYARD RD #32-401S RT ON STOCKYARD
 RD RT ON RAY BYRD 4TH LOT ON RT.JD

STRUCTURE: 000 000 28X70 3BR NO DECKS

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 MOBILE HOME YEAR : 1.00
 PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| T501 01 | 9/25/08 9/25/08 | JH DA | R*MOBILE HOME FOUND./ M. WALL VRU #: 001681584 Drain line has pvc & abs glued together and that is an illegal joint, not per code. |
| T501 02 | 9/30/08 9/30/08 | TI ARDT | R*MOBILE HOME FOUND./ M. WALL VRU #: 001683788 |

----- COMMENTS AND NOTES -----

ADDRESS : 76 RAY BYRD RD SUBDIV: STOCKYARD ESTATES
CONTRACTOR : RAVEN ROCK MOBILE HOME MOVER PHONE : (919) 775-3600
OWNER : RAY HUGH MICHAEL & SHEILA #32 PHONE : (910) 893-2246
PARCEL : 10-0559- - -0046- -39-
APPL NUMBER: 08-50019944 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : STOCKYARD RD #32-401S RT ON STOCKYARD
RD RT ON RAY BYRD 4TH LOT ON RT.JD

STRUCTURE: 000 000 28X70 3BR NO DECKS

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 MOBILE HOME YEAR : 1.00
PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|-----------------------------|--------------------|---|
| T501 01 | 9/25/08 9/25/08 | JH DA | R*MOBILE HOME FOUND./ M. WALL VRU #: 001681584 Drain line has pvc & abs glued together and that is an illegal joint, not per code. |
| T501 02 | 9/30/08 9/30/08 | DT AP | R*MOBILE HOME FOUND./ M. WALL VRU #: 001683788 |
| A814 01 | 11/06/08 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001701697 |
| Z818 01 | 11/06/08 <u>11/06/08</u> | TI <u>RB/AP</u> | PZ*ZONING INSPECTION TIME: 17:00 VRU #: 001701689 |

COMMENTS AND NOTES

ADDRESS : 76 RAY BYRD RD SUBDIV: STOCKYARD ESTATES
 CONTRACTOR : RAVEN ROCK MOBILE HOME MOVER PHONE : (919) 775-3600
 OWNER : RAY HUGH MICHAEL & SHEILA #32 PHONE : (910) 893-2246
 PARCEL : 10-0559- - -0046- -39-
 APPL NUMBER: 08-50019944 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
 DIRECTIONS : STOCKYARD RD #32-401S RT ON STOCKYARD
 RD RT ON RAY BYRD 4TH LOT ON RT.JD
 PREMISE # 18156713 *****

STRUCTURE: 000 000 28X70 3BR DWMH WITH 10X18 DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 MOBILE HOME YEAR : 1.00
 PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW
 WATER SUPPLY : COUNTY

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|--------------------------|--------------------|--|
| T501 01 | 9/25/08 9/25/08 | JH DA | R*MOBILE HOME FOUND./ M. WALL VRU #: 001681584 Drain line has pvc & abs glued together and that is an illegal joint, not per code. |
| T501 02 | 9/30/08 9/30/08 | DT AP | R*MOBILE HOME FOUND./ M. WALL VRU #: 001683788 |
| A814 01 | 11/06/08 11/07/08 | TI AP | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001701697 76 RAY BYRD RD LOT 32 |
| Z818 01 | 11/06/08 11/06/08 | RB AP | PZ*ZONING INSPECTION TIME: 17:00 VRU #: 001701689 |
| T507 01 | 12/09/08 12/09/08 | JH CA | R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 001714369 per Celestino |
| T507 02 | 1/06/09 1/06/09 | MR DA | R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 001723113 water under house. slope grade away from foundation to shed water house locked |
| T507 03 | 1/08/09 <u>1/8/09</u> | TI <u>AP DI</u> | R*MANUFACTURED HOME FINAL VRU #: 001723287 |

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Owner: Hugh Michael Ray

911 Address: 76 Ray Byrd Rd.

State: NC Zip Code: _____

Date: 1/8/09

[Signature]
Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

MFG. Home: 08-50019944

ADDRESS : 76 RAY BYRD RD SUBDIV: STOCKYARD ESTATES
CONTRACTOR : RAVEN ROCK MOBILE HOME MOVER PHONE : (919) 775-3600
OWNER : RAY HUGH MICHAEL & SHEILA #32 PHONE : (910) 893-2246
PARCEL : 10-0559- - -0046- -39-
APPL NUMBER: 08-50019944 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : STOCKYARD RD #32-401S RT ON STOCKYARD
RD RT ON RAY BYRD 4TH LOT ON RT.JD

STRUCTURE: 000 000 28X70 3BR DWMH WITH 10X18 DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 MOBILE HOME YEAR : 1.00
PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|----------------------------------|
| R131 01 | 1/05/09 | TI | ONE TRADE FINAL VRU #: 001722594 |
| | <u>1-5-9</u> | <u>AP-MR</u> | ADDED DECK TO FRONT OF DWMH |

----- COMMENTS AND NOTES -----

*Celestino
Zepeda*

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following: Front Porch Deck

Use Classification: R-3

PERMIT NUMBERS

Owner: Ray

Building Permit No.: 08-50019944

911 Address: _____

Electrical Permit No.: _____

76 Ray Byrd

Insulation Permit No.: _____

State: _____ Zip Code: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

Date: Mich Ream

MFG. Home: _____

Building Official