

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 8/7/08

Proposed Facility: 2 3600sqm HOMES Design Flow (.1949): 360 gpd each

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Witness/ Color	.1943 Soil Depth (IN.)	.1956 Saprot Class	.1944 Restr Horiz	
1	LS 2-3%	0-24"	G SL	VFR NS/NP					PS .45
		24-42"	SBK SCL	FR SS/S					
		42"	SBK CL	FR S/S	10FR 7/2 @ 42"				
2	HEAD SLOPE	0"	G SL	VFR NS/NP	BLACK w/ GRAY MOR.				US
		0"	G SL	VFR NS/NP	BLACK w/ GRAY MOR.				
4	LS 2-5%	0"	M C		CR 2 @ 2"				US
		0-12"	G SL	VFR NS/NP					
5		12-34"	SBK SCL	FR SS/S					PS .4
		34"	M CL						
		0-12"	G SL	VFR NS/NP					
6		12-36"	SBK SCL	FR SS/S					PS .45
		36"	SBK SCL	FR SS/S	10FR 7/2 @ 36"				
		0-20"	G SL	VFR NS/NP					
7		20-40"	SBK SCL	FR SS/S					PS .45

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25% R/B	D/MP 25% & LFG
Site LTAR	.45	.4

Other Factors (.1946): _____

Site Classification (.1948): PS

Evaluated By: JT

Others Present: