

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner: 09-500 21604

Applicant:

Address:

Date Evaluated:

Proposed Facility: ~~MTF~~ MTF

Design Flow (.1949): 360

Property Size:

Location of Site: 1214

Property Recorded:

Water Supply: Public Individual Well

Spring Other

Evaluation Method: Auger Boring Pit

Cut

Type of Wastewater: Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Witness/ Color	.1943 Soil Depth (IN.)	.1956 Saprod Class	.1944 Restr. Horiz.		
S D/L		0-18	GR SL	VFR S ⁺					.3	
		18-24	SBK JCL	FR S ⁰						
		24-36	SBK JC	FE S ⁺	CR 2 AT 32	32"				
		S, 6		0-20	GR SL	VFR S ⁼				.3
				20-24	SBK JCL	FR S ⁰				
				24-36	SBK JC	FE S ⁼	CR 2 A1 32	32"		
				0-26	GR SL	VFR S ⁼				.5
				26-38	SBK JCL	FR S ⁰				
				0-30	GR SL	VFR S ⁼				
		30-38	SBK JCL	FR S ⁼						
		0-24	GR SL	VF S ^D				.3		
		24-30	SBK JCL	FR S ^F						
30-36	SBK JC	FE S ⁼								
		0-18	GR SL	VFR S ^F				.3		
		18-38	SBK JCL	FR S ^F						
		38-48	SBK JC	FR S ⁺	CR 2 AT 32	32"				

Description	Initial System	Repair System
Available Space (.1945)	-	-
System Type(s)	Gravel	25%
Site LTAR	.3	.3

Other Factors (.1946): _____
 Site Classification (.1948): P
 Evaluated By: gwt
 Others Present:

At 18 max Ditch Depth