

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Sam Wesley Pitts
NEW [ ] REPAIR [x] EXPANSION [ ]
Type of Structure: Man. Home (28'x60')
Proposed Wastewater System Type: Existing
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement [ ] Yes [x] No
Pump Required: [ ] Yes [ ] No [ ] May be required based on final location and elevations of facilities
Type of Water Supply: [ ] Community [x] Public [ ] Well Distance from well 100 feet
Permit conditions:

PROPERTY LOCATION: ROBERTS RD
SUBDIVISION: QUAIL CREEK FARM LOT # 2
Site Improvements required prior to Construction Authorization Issuance:
THIS PERMIT IS FOR REPLACEMENT OF THE EXISTING SEPTIC TANK. THE EXISTING TANK HAS A BROKEN TOP AND IS COLLAPSING.
Permit valid for: [x] Five years [ ] No expiration

Authorized State Agent: [Signature] Date: 3/17/09 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Sam Wesley Pitts
Facility Type: Man. Home (28'x60') [ ] New [ ] Expansion [x] Repair
Basement? [ ] Yes [ ] No Basement Fixtures? [ ] Yes [ ] No
Type of Wastewater System\*\* Existing (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable [ ])

PROPERTY LOCATION: ROBERTS RD
SUBDIVISION: QUAIL CREEK FARM LOT # 2

Installation Requirements/Conditions

Septic Tank Size 1000 gallons
Pump Tank Size \_\_\_\_\_ gallons
Number of trenches Existing
Exact length of each trench \_\_\_\_\_ feet
Trench Spacing: \_\_\_\_\_ Feet on Center
Trenches shall be installed on contour at a Maximum Trench Depth of: \_\_\_\_\_ inches (Trench bottoms shall be level to +/-1/4" in all directions)
Soil Cover: \_\_\_\_\_ inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM
Aggregate Depth: \_\_\_\_\_ inches below pipe \_\_\_\_\_ inches above pipe \_\_\_\_\_ inches total
Conditions: REPLACING SEPTIC TANK

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 3/17/09
Construction Authorization Expiration Date: 3/17/14