

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 4 BED ROOMS Design Flow (.1949): 4000
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-2	0-10"	G S	VFL NSHP					
		10-11"	SBK C	FL S/P	1072 clae 12"				U3
2		0-12"	C S	VFL NSHP					
		12-14"	SBK C	FS S/P	1072 clae 12"				U5
3	LS 2-5	0-22"	C S	VFL NSHP					
		22-36"	SBK C	FL S/P	1072 - 12e 36"				PS .35
4		0-40"	G S	VFL NSHP					9.8
5		0-20"	G S	VFL NSHP					
		20-40"	SBK SCL	FL S/P					PS .4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OT Others Present: -
Available Space (.1945)		✓	
System Type(s)		Pump 25"	
Site LTAR		.35	

ATTEMPT TO REPAIR
 1x300" e 12-12"

