

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:

Applicant:

Date Evaluated: 8/15/69

Address:

Property Size:

Proposed Facility:

Design Flow (.1949):

Property Recorded:

Location of Site:

Public Individual

Well

Spring

Other

Water Supply:

Auger Boring

Pit

Cut

Evaluation Method:

Sewage

Industrial Process

Mixed

Type of Wastewater:

PROFILE #	.1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/Color	.1943 Soil Depth (IN.)	.1956 Saprot Class	.1946 Restr. Horiz	
1	LS 2-5%	0-22	G/SK	VF NS/MP					PS .3
		22-32	SBK/SCI	FR SS/SP	10YR 7/1 28"				
2		0-21	G/SK	VF NS/MP	10YR 7/1 22"				PS
3		0-24	G/SK	VF NS/MP					PS .3
		24-29	SBK/SCI	FR SS/SP	10YR 7/1 27"				
4		0-17	G/SK	VF NS/MP					PS .3
		17-32	SBK/SCI	FR SS/SP					
5		0-14	G/SK	VF NS/MP					PS
		14-20	SBK/C	VF: S P	10YR 7/1 17"				
6		0-10"	G SL						
		10-17"	SBK/C		10YR 7/1 @ 12"				
7		0-22"	G LS	VF NS/MP					PS .45
		22-39"	SBK/SCI	FR SS/SP	10YR 7/2 @ 39"				
8		0-22"	G LS	VF NS/MP					PS .45
		22-36"	SBK/SL	FR SS/SP	10YR 7/1 @ 34"				

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	PUMP 25" (1.06) .45	PUMP VENTILATED 25" (2.0) .3

Other Factors (.1946):

Site Classification (.1948): PS

Evaluated By: UT