HIE# 09-2-599915

Harnett County Department of Public Health

25657

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: Hwy27 ISSUED TO: THOMAG S LASATER SUBDIVISION LAKEFELD NEW 🔀 EXPANSION [] Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Man. Home (12376) Proposed Wastewater System Type: Conventiona 360 Projected Daily Flow: 3 Number of Occupants: S Number of bedrooms: Basement Yes Pump Required: □Yes ☐ May be required based on final location and elevations of facilities Type of Water Supply:
Community Public Well Distance from well 100 feet Permit valid for: Five years Permit conditions: ☐ No expiration The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: THOMAS S LASATER PROPERTY LOCATION: Hwy 27 SUBDIVISION LAKEFIELD LOT # Facility Type: MAN. HOME (1476) X New ☐ Expansion ☐ Repair Basement? Yes No Basement Fixtures? Yes Type of Wastewater System** CONVENTIONAL _____ (Initial) Wastewater Flow: 360 GPD (See note below, if applicable DURILLIAM (Repair) Installation Requirements/Conditions Number of trenches Septic Tank Size 1000 gallons Exact length of each trench 100 Trench Spacing: 9 Feet on Center feet Pump Tank Size gallons Trenches shall be installed on contour at a Soil Cover: 6-12 inches Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. GPM 6 _ inches below pipe Conditions: WATERLINE MUST BE 10' FROM ALL PARTS OF THE SEPTIC STATEMS ALL OTHER UTILITIES MAY NOT ENGROACH ON ANY PARKS OF THE SEPTIC SYSTEMS **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This pravisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date:

HTE#	O9-	5-22	412	

Permit # _ 25(57

Harnett County Department of Public Health Site Sketch

