

HTE# 09-522856

Harris County Department of Public Health

25676

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: SHERICA McCoyPROPERTY LOCATION: MILTON WELCH RDSUBDIVISION KNOLL BROOK EST.LOT # 16NEW ☒ REPAIR ☐ EXPANSION ☐

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: MAN. HOME (28x56)Proposed Wastewater System Type: CONVENTIONALProjected Daily Flow: 360 GPDNumber of bedrooms: 3 Number of Occupants: 6 maxBasement ☐ Yes ☒ NoPump Required: ☐ Yes ☐ No ☒ May be required based on final location and elevations of facilitiesType of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well 100 feetPermit valid for: ☒ Five years
☐ No expiration

Permit conditions:

Authorized State Agent:

RENSDate: 9/23/09

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: SHERICA McCoyPROPERTY LOCATION: MILTON WELCH RDSUBDIVISION KNOLL BROOK EST.LOT # 16Facility Type: MAN. HOME (28x56) ☒ New ☐ Expansion ☐ RepairBasement? ☐ Yes ☒ No Basement Fixtures? ☐ Yes ☒ NoType of Wastewater System** CONVENTIONAL (Initial) Wastewater Flow: 360 GPD(See note below, if applicable ☐)CONVENTIONAL (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Pump Tank Size _____ gallons

Number of trenches 3Exact length of each trench 80 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: 19-28 inches(Trench bottoms shall be level to $\pm 1/4"$

in all directions)

Trench Spacing: 9 Feet on CenterSoil Cover: 6-16 inches(Maximum soil cover shall not exceed
36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: 6 inches below pipe
2 inches above pipe
12 inches total

Conditions: _____

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This

Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent:

RENSDate: 9/23/09Construction Authorization Expiration Date: 9/23/14

HTE# 095-22856

Permit # 25676

Harnett County Department of Public Health Site Sketch

ISSUED TO: SHERICA MCGY PROPERTY LOCATOR: MILTON WELCH RD
SUBDIVISION KNOLLBROOK EST. LOT # 46

Authorized State Agent: REHS (OLIVER TOLKSPORF) Date: 9/23/09

DRAWING
N/S

