

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: Date Evaluated: 10/22/09

Proposed Facility: 3 BESDEN HOME Design Flow (.1949):

Property Size:

Location of Site: Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	40-8%	0-18"	G LS	VFL NS/NP					
		18-32"	SBK SCL	FL SS/SF					PS.2
		32"	PM						
2		0-20"	G LS	VFL NS/NP					
		20-32"	SBK SCL	FL SS/SF					PS.4
		32"	PM						
3		0-18"	G LS	VFL NS/NP					
		18-32"	SBK SCL	FL SS/SF					PS.4
		32"	PM						
4		0-21"	G LS	VFL NS/NP					
		21-32"	SBK SCL	FL SS/SF					PS.4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): ES Evaluated By: OS Others Present: —
Available Space (.1945)	✓	✓	
System Type(s)	CON	CON	
Site LTAR	.4	.4	

3x100 @ 18"