

HTE# 09-523281

# Harnett County Department of Public Health

25775

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: TIFFANY MOCK PROPERTY LOCATION: BROADWAY SWANN SR

NEW  REPAIR  EXPANSION  SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

Type of Structure: MAN. HOME (14x70') Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_

Proposed Wastewater System Type: CONVENTIONAL

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well 100 feet

Permit conditions: \_\_\_\_\_ Permit valid for:  Five years  No expiration

Authorized State Agent: ~~\_\_\_\_\_~~ REAS Date: 11/23/09 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: TIFFANY MOCK PROPERTY LOCATION: BROADWAY SWANN SR

FACILITY TYPE: MAN. HOME (14x70')  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* CONVENTIONAL (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable  CONVENTIONAL (Repair))

<b>Installation Requirements/Conditions</b>	Number of trenches <u>3</u>	
Septic Tank Size <u>1000</u> gallons	Exact length of each trench <u>100</u> feet	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size _____ gallons	Trenches shall be installed on contour at a	Soil Cover: <u>6</u> inches
	Maximum Trench Depth of: <u>18</u> inches	(Maximum soil cover shall not exceed 36" above the trench bottom)
	(Trench bottoms shall be level to +/- 1/4" in all directions)	

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

Aggregate Depth: 6 inches below pipe 2 inches above pipe 12 inches total

Conditions: WATER LINE MUST BE 10' FROM SEPTIC SYSTEM. NO UTILITIES MAY ENCRUACH OR INITIAL OR REPAIR AREA. PIPE UNDER DRIVE MUST BE SLEEVED W/ SCH 80 PIPE

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: ~~\_\_\_\_\_~~ REAS Date: 11/23/09

Construction Authorization Expiration Date: 11/23/14

HTE# 09-5-23281

Permit # 25775

# Harnett County Department of Public Health Site Sketch

ISSUED TO: TIFFANY MCLIC PROPERTY LOCATOR: BROADWAY RD  
SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

Authorized State Agent: \_\_\_\_\_ RENS (OLIVER TOLKSPOR) Date: 11/23/09



