Harnett County Department of Public nealth

25715

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: SA 1560 Festus 12D SUBDIVISION KENNETH TO HUSON NEW EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Proposed Wastewater System Type: 25% 12 Forces Projected Daily Flow: 360 GPD Number of Occupants: Number of bedrooms: 3 Basement Yes Pump Required: Tes No May be required based on final location and elevations of facilities Type of Water Supply:

Community Public Well Distance from well feet Permit valid for: Five years Permit conditions: ☐ No expiration Authorized State Agent:: SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. Facility Type: ______ Dew ____ Repair PROPERTY LOCATION: SZ 1560 Feefur RD SUBDIVISION Kentrett TOHISTON Type of Wastewater System** (Initial) Wastewater Flow: 360 GPD (See note below, if applicable

) 25% REDUCTION SASTEL (Repair) Installation Requirements/Conditions Septic Tank Size 1000 gallons Pump Tank Size __/ODO _ gallons Maximum Trench Depth of: 24 - > /8 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) 6 inches below pipe Pump Requirements: ft. TDH vs. Aggregate Depth: 2 inches above pipe Conditions: EX Dell MUST BG Felled prior to Septic **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date: Z-19-15

Harnett County Department of Public Health Site Sketch

ISSUED TO: Shizley Johnson SUBDIVISION Kenneth Johnson LOT # 2

Authorized State Agent: James E Montant Date: 2-19-10

