

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: *3800000* Design Flow (.1949): *360 gpd* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>LS 5-10%</i>	<i>0-36"</i>	<i>G S</i>	<i>VFC NS/HP</i>					
		<i>36-48"</i>	<i>SBL SL/SL</i>	<i>F2 SS/SP</i>					<i>PS.6</i>
2		<i>0-48"</i>	<i>G S</i>	<i>VFC NS/HP</i>					<i>PS.8</i>
3		<i>0-48"</i>	<i>G S</i>	<i>VFC NS/HP</i>					<i>PS.8</i>
4		<i>0-36"</i>	<i>G S</i>	<i>VFC NS/HP</i>					
		<i>36-48"</i>	<i>SBL SL/SL</i>	<i>F2 SS/SP</i>					<i>PS.6</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>[Signature]</i> Others Present:
Available Space (.1943)	<i>COF</i>	<i>COF</i>	
System Type(s)	<i>COF</i>	<i>COF</i>	
Site LTAR	<i>6</i>	<i>5</i>	