

SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
 Address: Date Evaluated: 1/9/10
 Proposed Facility: Sewer Design Flow (.1949): 600 gpd
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L02	0-4"	CS	VFA NS/NP					PS 8
2		0-29" 29-40"	G S SBK* CL	VFA NS/NP FR SS/SP					PS 5
3		0-29" 29-42"	G S SBK* CL	VFA NS/NP FR SS/SP					PS 5
4		0-31" 31"	G S SBK* SCL	VFA NS/NP FR SS/SP	RED OX FEATURES START @ 31"				

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OK Others Present: _____
Available Space (.1943)	✓	✓	
System Type(s)	CON	CON	
Site LTAR	.5	.5	

FIND LAYOUT WHEN HOUSE SITE CLEARED