
ADDRESS . . : 1956 BALLARD RD
 CONTRACTOR : COOPERS MOBILE HOME MOVING SER
 OWNER . . . : AVERY RONNIE G & LORETTA L
 PARCEL . . . : 08-0652- - -0044- - -
 APPL NUMBER: 11-50026116 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
 DIRECTIONS : T/S: 02/22/2011 08:51 AM VBROWN ----
 SWMH ON SAME PARCEL AS 2ND HOME NEXT TO
 1938 BALLARD ROAD. 401N GOING TOWARD
 FUQUAY VARINIA, RIGHT ON BALLARD RD 3
 TO 4MI, HOMESITE WILL BE ON RIGHT
 BESIDE OLDER BROWN SWMH, NEAR OPPOSITE
 END OF BALLARD.

STRUCTURE: 000 000 14X76 3BDR SWMH
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 PROPOSED USE : SWMH
 WATER SUPPLY : COUNTY

MOBILE HOME YEAR : 1000.00
 SEPTIC - EXISTING? : NEW TANK

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
T501 01	<u>3/10/11</u> <u>3-10-11</u>	TI <u>APBS</u>	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002052256 T/S: 03/09/2011 01:35 PM VBROWN

----- COMMENTS AND NOTES -----

ADDRESS . . : 1956 BALLARD RD
CONTRACTOR : COOPERS MOBILE HOME MOVING SER
OWNER . . . : AVERY RONNIE G & LORETTA L
PARCEL . . . : 08-0652- - -0044- - -
APPL NUMBER: 11-50026116 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : T/S: 02/22/2011 08:51 AM VBROWN ----
SWMH ON SAME PARCEL AS 2ND HOME NEXT TO
1938 BALLARD ROAD. 401N GOING TOWARD
FUQUAY VARINIA, RIGHT ON BALLARD RD 3
TO 4MI, HOMESITE WILL BE ON RIGHT
BESIDE OLDER BROWN SWMH, NEAR OPPOSITE
END OF BALLARD.

STRUCTURE: 000 000 14X76 3BDR SWMH
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 MOBILE HOME YEAR : 1000.00
PROPOSED USE : SWMH SEPTIC - EXISTING? : NEW TANK
WATER SUPPLY : COUNTY

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	3/10/11	BS	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002052256
	3/10/11	AP	T/S: 03/09/2011 01:35 PM VBROWN ----- Cannot support conduit on blocks. Install 2 more treated supports and use proper straps. Will check at final inspection
Z818 01	3/21/11	TI	PZ*ZONING INSPECTION VRU #: 002056045
	<u>3-21-11</u>	<u>R.B./AP</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 1956 BALLARD RD SUBDIV:
 CONTRACTOR : COOPERS MOBILE HOME MOVING SER PHONE : (919) 553-6602
 OWNER : AVERY RONNIE G & LORETTA L PHONE : (919) 552-7924
 PARCEL : 08-0652- - -0044- - -
 APPL NUMBER: 11-50026116 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
 DIRECTIONS : T/S: 02/22/2011 08:51 AM VBROWN ----
 SWMH ON SAME PARCEL AS 2ND HOME NEXT TO
 1938 BALLARD ROAD. 401N GOING TOWARD
 FUQUAY VARINIA, RIGHT ON BALLARD RD 3
 TO 4MI, HOMESITE WILL BE ON RIGHT
 BESIDE OLDER BROWN SWMH, NEAR OPPOSITE
 END OF BALLARD.

STRUCTURE: 000 000 14X76 3BDR SWMH
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 MOBILE HOME YEAR : 1000.00
 PROPOSED USE : SWMH SEPTIC - EXISTING? : NEW TANK
 WATER SUPPLY : COUNTY

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	3/10/11 3/10/11	BS AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002052256 T/S: 03/09/2011 01:35 PM VBROWN ---- Cannot support conduit on blocks. Install 2 more treated supports and use proper straps. Will check at final inspection
Z818 01	3/21/11 3/21/11	RB AP	PZ*ZONING INSPECTION VRU #: 002056045 T/S: 03/21/2011 11:30 AM RBAKER ----
H824 01	3/21/11 3/21/11	JM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002057032 T/S: 03/21/2011 11:59 AM SZIMMER ---- T/S: 03/21/2011 12:00 PM SZIMMER ----
T507 01	3/25/11 <u>3-25-11</u>	TI <u>APBS</u>	R*MANUFACTURED HOME FINAL VRU #: 002058427
A814 01	3/25/11 3/23/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002056054 ✓ 1956 BALLARD RD FUQUAY VARINA 27526 ---- T/S: 03/23/2011 10:32 AM TWARD ---- T/S: 03/23/2011 10:32 AM TWARD ----

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD Manuf 1x

Permit Numbers

Name: Ronnie & Loretta Avery

Building: _____

Electrical: _____

Address: 1956 Ballard Road

Insulation: _____

Fuquay Varina NC 27526

Plumbing: _____

Mechanical: _____

MFG Home: 11-50026116

Date: 02-25-2011

Building Official: BSutton