

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:

Address:

Proposed Facility: *↳ 36000 m²*

Location of Site:

Water Supply:

Evaluation Method:

Type of Wastewater:

Date Evaluated: *4/13/11*

Design Flow (.1949): *480 gpd*

Property Recorded:

Property Size:

- Public Individual Well Spring Other
 Auger Boring Pit Cut
 Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>L₅ 5-7% ↓</i>	<i>0-22</i>	<i>G S</i>	<i>VFR N3/4P</i>					<i>P₅ H</i>
		<i>22-36^{11"}</i>	<i>SBK SCL</i>	<i>F1 Ss/SP</i>	<i>10-12 7/2 @ 34"</i>				
2		<i>0-20</i>	<i>G SL</i>	<i>VFR N3/4P</i>					<i>P₅ H</i>
		<i>20-34^{11"}</i>	<i>SBK SCL</i>	<i>F1 Ss/SP</i>	<i>10-12 7/2 @ 32"</i>				
3		<i>0-17</i>	<i>G S</i>	<i>VFR N3/4P</i>					<i>P₅ H</i>
		<i>18-32^{11"}</i>	<i>SBK SCL</i>	<i>F1 Ss/SP</i>	<i>10-12 7/2 @ 31"</i>				

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>P₅</i> Evaluated By: <i>OT</i> Others Present:
Available Space (.1945)	<i>✓</i>	<i>✓</i>	
System Type(s)	<i>25%</i>	<i>25%</i>	
Site LTAR	<i>25%</i>	<i>25%</i>	

3x100 @ 18" MAX!