Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 7/6/2011
Proposed Facility: 3 BEDROOMS Design Flow (.1949): 360 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☐ Auger Boring ☑ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz.	
Pit 1	LS 8%	0-16	G/LS	VFr NSNP					
		16-42	SBK/C	Fi SP	10YR7/2 @ 37"				PS 3
2		0-22	G/LS	VFr NSNP					
		22-42	SBK/C	Fi SP	10YR7/2 @ 37"				PS 3
3		0-21	G/LS	VFr NSNP					
		21-40	SBK/C	Fi SP	10YR7/2 28"				US/PS 3

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25% RED	→
Site LTAR	.3	.3

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: OT
Others Present: BM