
ADDRESS : 570 TAYLOR RD SUBDIV: FLOYD E THOMAS EST MAP #2
 CONTRACTOR : NORMANS INSTALLATION CO INC PHONE : (919) 738-1939
 OWNER : COATS EVERETTE PHONE : (910) 814-3253
 PARCEL : 01-0505- - -0025- -05-
 APPL NUMBER: 11-50027125 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
 DIRECTIONS : T/S: 07/14/2011 09:10 AM JBROCK ----
 GO N FORM SPRING LAKE ON HWY 82 3 MILES
 TO NURSERY RD ON RIGHT TURN RIGHT TAKE
 NURSERY RD GO 2.5 MILES AND TUR NLEFT
 THIS IS STILL NURSERY RD GO 3 MORE
 MILES ON NURSERY RD TO TAYLOR RD ON
 LEFT TURN LEFT TAKE TAYLOR RD ONE MILE
 TO LOT 4C ON RIGHT TAYLOR RD BECOMES
 DIRT THE LAST 1/2 MILE
 T/S: 05/30/2013 08:42 AM VBROWN ----
 ON HD FRONT PORCH BUILT NO PERMITS, REV

STRUCTURE: 000 000 28X48 3BDR DWMH

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 MOBILE HOME YEAR : 1.00
 PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW
 WATER SUPPLY : COUNTY

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	4/30/12 4/30/12	DT DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002221273 T/S: 04/30/2012 11:44 AM DETAYLOR ----- No test on plumbing
T501 02	5/30/13 5/30/13	JH AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002388668 T/S: 05/29/2013 08:05 AM VBROWN -----
H824 01	9/26/13 9/26/13	OT DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002445237 T/S: 09/26/2013 11:34 AM SSTEWARD ----- PER OLIVER TOLKSDORF, OPERATIONS PERMIT ON HOLD FOR SEPTIC - NEEDS PUMP AND ALARM TO BE CHECKED. CALL OLIVER AT 893-7547 WHEN READY FOR INSPECTION.
A814 01	6/03/14 6/04/14	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002535417 570 TAYLOR RD SPRING LAKE 28390 T/S: 06/04/2014 04:31 PM TWARD ----- T/S: 06/04/2014 04:31 PM TWARD -----
Z818 01	6/03/14 6/03/14	RB AP	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002535409 T/S: 06/02/2014 08:38 AM LSEGARS ----- T/S: 06/04/2014 08:26 AM DJOHNSON -----
H828 01	6/11/14 6/11/14	BM AP	ENVIRO. WELL PERMIT TIME: 17:00 VRU #: 002540102 T/S: 06/11/2014 10:08 AM SSTEWARD ----- T/S: 06/11/2014 10:09 AM SSTEWARD -----
H824 02	7/29/14 7/29/14	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002561090 T/S: 07/30/2014 12:44 PM SSTEWARD ----- T/S: 07/30/2014 12:44 PM SSTEWARD -----
T507 01	11/03/14 <u>11</u>	TI <u>DA-MR</u>	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002594422 T/S: 10/30/2014 12:47 PM DJOHNSON -----

----- COMMENTS AND NOTES -----