RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2179

1. WELL CONTRACTOR:

Roger W. Jackson
Well Contractor (Individual) Name

Jackson Well Company
Well Contractor Company Name

STREET ADDRESS 5660 McDougald Road

Lillington, North Carolina 27546
City or Town State Zip Code

(910) 893-2372
Area code- Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) Pn 0505-29-5203,000

STATE WELL PERMIT #(if applicable) App 11-5-27125

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply ☑

DATE DRILLED 4-25-12

TIME COMPLETED 2:00 AM☐ PM☑

3. WELL LOCATION:

CITY: Spring Lake COUNTY Harnett

386 Taylor Rd 28390
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

☑Slope ☐Valley ☐Flat ☐Ridge ☐ Other
(check appropriate box)

LATITUDE 35 35.006

LONGITUDE 78 61.906

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☑GPS ☐Topographic map

(location of well must be shown on a USGS topo map and *attached to this form if not using GPS)*

4. WELL OWNER

OWNER'S NAME John C. Pavlikianidio

STREET ADDRESS 386 Taylor Rd.

Spring Lake NC. 28390
City or Town State Zip Code

(910) 364 8031
Area code- Phone number

5. WELL DETAILS:

a. TOTAL DEPTH: 180'

b. DOES WELL REPLACE EXISTING WELL? YES☐ NO☑

c. WATER LEVEL Below Top of Casing: 31 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS + FT. Above Land Surface*
*Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118.

e. YIELD (gpm): 30 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 12 oz

g. WATER ZONES (depth):

From	To	From	To
152	154		

6. CASING:

From	To	Ft.	Diameter	Thickness/ Weight	Material
0	104		6 5/8	SR21	PVC

7. GROUT:

From	To	Ft.	Material	Method

8. SCREEN:

From	To	Ft.	Diameter in.	Slot Size in.	Material

9. SAND/GRAVEL PACK:

From	To	Ft.	Size	Material

10. DRILLING LOG

From	To	Formation Description
0	89	CLAY
89	180	SLATE

11. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Roger W. Jackson 4-27-12
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

Roger W. Jackson
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.,

Form GW-1a