Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 9/2/2011
Proposed Facility: Design Flow (.1949): Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	5%	0-18	G/SL	VFr NSNP					
		18-32	SBK/SC	Fr SSP	10YR7/1 28"				PS.3
		0-10	G/SL	VFr NSNP					
		10-30	SBK/SC	Fr SSP	10YR5/1 28"				PS 3

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	Pump to Cons.	pump to cons.
Site LTAR	.3	.3

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: [illegible]
Others Present: