HTE# 11-5-27528

## Harnett county Department of Public He

Improvement Permit

26765

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: Kansawhn. O. Butler SUBDIVISION NEW 🗹 Site Improvements required prior to Construction Authorization Issuance: REPAIR 32x76 25 To Reduction System Type of Structure: SFD Proposed Wastewater System Type: Projected Daily Flow: 480 Number of Occupants: 8 max Number of bedrooms: 4 Basement Yes Pump Required: ☐Yes 1 No ☐ May be required based on final location and elevations of facilities Type of Water Supply: 

Community Public Well Distance from well feet Five years Permit valid for: ■ No expiration Permit conditions: Authorized State Agent:: SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: William O. Butler PROPERTY LOCATION: Ransaw SUBDIVISION SUBDIVISION \_\_\_\_\_ Repair Basement Fixtures? Tyes No. (Initial) Wastewater Flow: 480 Basement Fixtures? 

Yes Basement? Yes Type of Wastewater System\*\* (See note below, if applicable 

) 25 % Reduction System (Repair) Number of trenches 3 Installation Requirements/Conditions Exact length of each trench \_\_\_\_\_\_ feet Trench Spacing: \_\_\_\_\_ Feet on Center Septic Tank Size /OOO gallons Pump Tank Size gallons Trenches shall be installed on contour at a Soil Cover: 12-24 Maximum Trench Depth of: 24-36 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. GPM inches below pipe Aggregate Depth: \_\_\_\_\_\_ inches above pipe Conditions: inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Luga Mucing REHS Construction Authorization Expiration Date: 10/26/246

## Harnett County Department of Public Health Site Sketch

