

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:**   X  

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential  
Name: Meraz Walter Naup Mercia

**Permit Numbers**

Building: \_\_\_\_\_  
Electrical: \_\_\_\_\_  
Insulation: \_\_\_\_\_  
Plumbing: \_\_\_\_\_  
Mechanical: \_\_\_\_\_  
MFG Home: 17-50029256

Address: 120 Brinkley Rd  
Dunn, NC 28334

**Date:** 11-2-17

**Building Official:** [Signature]

-----  
ADDRESS : 120 BRINKLEY RD SUBDIV:  
CONTRACTOR : CHOO'S MOBILE HOME TRANSIT PHONE : (910) 850-6572  
OWNER : MERAZ WALTER NAUN MENCIA PHONE : (919) 902-8630  
PARCEL : 02-1518- - -0020- -17-  
APPL NUMBER: 12-50029256 CP MANUFACTURED HOME RA20R/RA20M CRITERIA  
DIRECTIONS : T/S: 06/28/2012 09:49 AM VBROWN ----  
120 BRINKLY RD DUNN, 421S, LEFT ON RED  
HILL CH RD, RIGHT ON THREE BRIDGES RD,  
LEFT ON OLD FAIR GRD RD, RIGHT ON  
BRINKLEY RD, LOT IS BETWEEN 102 AND 104  
BRINKLEY RD.  
-----

**STRUCTURE: 000 000 28X48 4BDR DWMH**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00 MOBILE HOME YEAR : 2000.00  
PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW TANK  
WATER SUPPLY : COUNTY  
-----

**PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	3/29/17	KS	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002950608
	3/29/17	DA	T/S: 03/27/2017 02:05 PM JBROCK ----- 01.: 03/29/2017 03:03 PM KSLATTUM ----- 1. I beam not bonded 2. no longitudinal ties 3. conduit needs support 4. repair plastic under home
T501 02	4/19/17	DT	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002960508
	4/19/17	AP	T/S: 04/17/2017 03:12 PM LBENNETT ----- T/S: 04/19/2017 11:31 AM DETAYLOR -----
A814 01	4/20/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002961589
	4/20/17	AP	120 BRINKLEY RD DUNN 28334 T/S: 04/20/2017 11:30 AM SBENNETT -----
P307 01	4/20/17	DT	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002961563
	4/20/17	AP	T/S: 04/19/2017 11:32 AM JBROCK ----- T/S: 04/20/2017 11:06 AM DETAYLOR -----
H824 01	10/31/17	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003047479
	10/31/17	AP	T/S: 10/31/2017 10:45 AM KHINSON ----- T/S: 10/31/2017 10:45 AM KHINSON -----
Z818 01	10/31/17	RB	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 003046786
	10/31/17	AP	T/S: 10/30/2017 09:51 AM LLUCAS ----- T/S: 10/31/2017 11:21 AM DJOHNSON -----
T507 01	11/02/17	TI	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 003047891
	11/2/17	AP DT	T/S: 10/31/2017 04:26 PM LLUCAS -----

----- COMMENTS AND NOTES -----