

PREPARED 9/17/12, 14:36:30
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 21
DATE 9/18/12

ADDRESS : 91915 *UNASSIGNED SUBDIV:
CONTRACTOR : ENTERPRISE MOBILE HOME CONTR PHONE : (910) 893-9268
OWNER : KOERNER FLOYD JR & WIFE PHONE : (910) 723-4622
PARCEL : 12-0556- - -0251- -03-
APPL NUMBER: 12-50029514 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : T/S: 08/07/2012 10:49 AM JBROCK ----
TAKE 401 S AND GO PAST BUNNLEVEL THEN
TAKE R ON BYRDS POND RD GO 1.4 MILES
AND TAKE LEFT AT VICTORY LN AND GO TO
212 VICTORY ACROSS FORM POND

STRUCTURE: 000 000 28X56 2BDR DWMH

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 2000000.00 MOBILE HOME YEAR : 1000000.00
PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW TANK
WATER SUPPLY : EXT WELL

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	8/30/12	JH	R*MOBILE HOME FOUND./ M. WALL VRU #: 002272873
	8/30/12	CA	PER FLOYD He thought he needed a footing inspection.-----
T501 02	9/18/12	TI	R*MOBILE HOME FOUND./ M. WALL VRU #: 002279518

9-18-12 DA JH

----- COMMENTS AND NOTES -----

PREPARED 10/23/12, 14:03:25
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 35
DATE 10/24/12

ADDRESS . : 214 VICTORY LN
CONTRACTOR : ENTERPRISE MOBILE HOME CONTR
OWNER . . : KOERNER FLOYD JR & WIFE
PARCEL . . : 12-0556- - -0251- -03-
APPL NUMBER: 12-50029514 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : T/S: 08/07/2012 10:49 AM JBROCK ----
TAKE 401 S AND GO PAST BUNNLEVEL THEN
TAKE R ON BYRDS POND RD GO 1.4 MILES
AND TAKE LEFT AT VICTORY LN AND GO TO
212 VICTORY ACROSS FORM POND

STRUCTURE: 000 000 28X56 2BDR DWMH

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 2000000.00
PROPOSED USE : DWMH
WATER SUPPLY : EXT WELL
MOBILE HOME YEAR : 1000000.00
SEPTIC - EXISTING? : NEW TANK

PERMIT: CPLU 00 CP LAND USE PERMIT

	REQUESTED	INSP	DESCRIPTION
TYP/SQ	COMPLETED	RESULT	RESULTS/COMMENTS
Z818 01	10/24/12	TI	PZ*ZONING INSPECTION VRU #: 002294458
	<u>10/24/12</u>	<u>RB/AP</u>	

----- COMMENTS AND NOTES Cost 126760 -----

PREPARED 10/24/12, 14:20:27
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 41
DATE 10/25/12

ADDRESS : 214 VICTORY LN
CONTRACTOR : ENTERPRISE MOBILE HOME CONTR
OWNER : KOERNER FLOYD JR & WIFE
PARCEL : 12-0556- -0251- -03-
APPL NUMBER: 12-50029514 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : T/S: 08/07/2012 10:49 AM JBROCK ----
TAKE 401 S AND GO PAST BUNNLEVEL THEN
TAKE R ON BYRDS POND RD GO 1.4 MILES
AND TAKE LEFT AT VICTORY LN AND GO TO
212 VICTORY ACROSS FORM POND

SUBDIV:
PHONE : (910) 893-9268
PHONE : (910) 723-4622

STRUCTURE: 000 000 28X56 2BDR DWMH

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 2000000.00
PROPOSED USE : DWMH
WATER SUPPLY : EXT WELL

MOBILE HOME YEAR : 1000000.00
SEPTIC - EXISTING? : NEW TANK

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	8/30/12	JH	R*MOBILE HOME FOUND./ M. WALL VRU #: 002272873
	8/30/12	CA	PER FLOYD He thought he needed a footing inspection.-----
T501 02	9/18/12	JH	R*MOBILE HOME FOUND./ M. WALL VRU #: 002279518
	9/18/12	DA	1)Drain lines need to be installed & have drian line test per code.2)Strap drain line every 4' per code.3)Water line needs to be installed with cutoff & prv & insulate water line.
H824 01	9/20/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002281863
	9/20/12	AP	T/S: 09/21/2012 10:09 AM SSTEWARD ----- T/S: 09/21/2012 10:09 AM SSTEWARD -----
T501 03	9/21/12	JH	R*MOBILE HOME FOUND./ M. WALL VRU #: 002281024
	9/21/12	AP	
A814 01	9/24/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002281848
	10/03/12	AP	214 VICTORY LN ERWIN 28339----- # TO BE POSTED ON HOME AND BY DRIVE AT ENTRANCE BY 212 T/S: 10/03/2012 02:30 PM TWARD -----
T507 01	10/25/12	TI	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002295202
	10-25-12	DA JH	T/S: 10/24/2012 10:25 AM VBROWN -----

COMMENTS AND NOTES