

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 3650 RIVER      Design Flow (.1949): 360 gpd      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well       Spring       Other  
 Evaluation Method:  Auger Boring       Pit       Cut  
 Type of Wastewater:                       Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5%	0-16"	G S	VF2 NS/VP					
		16"	SBK SCL	F2 SS/SP	10YR 7/2 @ 22"				US
2		0-10"	G S	VF2 NS/VP					
		10"	SBK SCL	F2 SS/SP	10YR 7/2 @ 18"				US
3		0-18"	G S	VF2 NS/VP					
		18"	SBK SCL	F2 SS/SP	10YR 7/2 @ 22"				US
4		0-22"	G SL	VF2 NS/VP					
		22-32"	SBK SCL	F2 SS/SP	10YR 7/2 @ 32"				PS 4
5		0-24"	G SL	VF2 NS/VP					
		24-36"	SBK SCL	F2 SS/SP	10YR 7/2 @ 32"				PS 4
6		0-30"	G SL	VF2 NS/VP					
		30-36"	SBK SCL	F2 SS/SP	10YR 7/2 @ 32"				PS 4

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948): <u>PS</u>
System Type(s)	<u>2 5% PLS</u>	<u>PLS</u>	Evaluated By: <u>EM</u>
Site LTAR	<u>PS</u>	<u>PS</u>	Others Present: <u>EM</u>