

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 3 bedrooms      Design Flow (.1949): 360 gpd  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	024	G S	VF2 NS/MP					
		2444	SBK SCL	FR SS/SP	10727/20 42"				P3 .45
2		030	G S	VF2 NS/MP					
		3044"	SBK SCL	FR SS/SP	10727/20 42"				P3 .45

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P3 Evaluated By: [Signature] Others Present: [Signature]
Available Space (.1945)	✓	✓	
System Type(s)	25% RFD		
Site LTAR	.45	.45	

1x200' @ 20'-30'