Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 3/15/2013
Proposed Facility: Design Flow (.1949): Property Size:
Location of Site: Property Recorded:
Water Supply: ☐ Public ☐ Individual ☑ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	LS 3%	0-22	G/LS	VFr NSNP					
		22-35	SBK/SCL	Fr SSSP					PS.5
		35 Rock							
			Pit						
		0-20	G/LS	VFr NS NP					
		20-48	SBK/SCL	Fr SSSP	10YR 7/1 @ 36"				PS.5
		0-21	G/LS	VFr NS NP					
		21-48	SBK/SCL	Fr SSSP	10YR 7/1 @ 31"				PS.5

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	25 E.	25 E.
Site LTAR	.5	.5

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: BM
Others Present: