

HTE# 13-5-31794

# Hamilton County Department of Public Health

27496

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: Wire Rd

ISSUED TO: Timothy Ray + Betty Sue Ivey

SUBDIVISION \_\_\_\_\_

LOT # \_\_\_\_\_

NEW  REPAIR  EXPANSION

Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_

Type of Structure: MH 14x76

Proposed Wastewater System Type: 25% Reduction System

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet

Permit valid for:  Five years

Permit conditions: \_\_\_\_\_

No expiration

Authorized State Agent: Bryan McSwain, RCHS

Date: 8/7/2013

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Timothy Ray + Betty Sue Ivey

PROPERTY LOCATION: Wire Rd

SUBDIVISION \_\_\_\_\_

LOT # \_\_\_\_\_

Facility Type: MH 14x76  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* 25% Reduction System (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable )

25% Reduction System (Repair)

### Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Number of trenches 2 or 3

Pump Tank Size \_\_\_\_\_ gallons

Exact length of each trench 75 or 50 feet

Trench Spacing: 9 Feet on Center

Trenches shall be installed on contour at a Maximum Trench Depth of: 36-18 18-72 inches

Soil Cover: 18-6 inches

(Trench bottoms shall be level to +1-1/4" in all directions)

(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

Aggregate Depth: \_\_\_\_\_ inches below pipe

Conditions: Start ditches at 18 inches

Aggregate Depth: \_\_\_\_\_ inches above pipe

Aggregate Depth: \_\_\_\_\_ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.**

**NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_

Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: Bryan McSwain, RCHS

Date: 8/7/2013

Construction Authorization Expiration Date: 8/7/2018

HTE# 13-5-31794

Permit # 27496

# Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: Wire Rd

ISSUED TO: Timothy Ray + Betty Sue Ivey SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

Authorized State Agent: Greg McSwain, RENS Date: 8/7/2013

