HTE# 13-5-32540

Harnett County Department of Public Health

27760

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: LESLIE RD ISSUED TO: CHARLES HUDSON SUBDIVISION NEW REPAIR DEXPANSION DO Type of Structure: MAN HOME (121 × 80) Site Improvements required prior to Construction Authorization Issuance: Proposed Wastewater System Type: Conventional Projected Daily Flow: 360 GPD Number of Occupants: __ C max Number of bedrooms: Pump Required:

Yes No
May be required based on final location and elevations of facilities * Type of Water Supply:

Community Public Well Distance from well 100 feet Permit valid for: Five years Permit conditions: ☐ No expiration READ Date: _ Authorized State Agent:: SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: CHARLES HUDSON PROPERTY LOCATION: LETLIE KO Facility Type: Man Home (12/280) New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** (Initial) Wastewater Flow: 360 GPD (See note below, if applicable \square) MANOIMAN Installation Requirements/Conditions Number of trenches ___ Exact length of each trench ____? 5 feet Septic Tank Size | O O gallons Soil Cover: 6-24 Pump Tank Size gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18-36 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) Pump Requirements: ______ft. TDH vs. _____ GPM _____ inches below pipe Aggregate Depth: ______ inches above pipe _____ inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: ___ This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Construction Authorization Expiration Date: ___

HTE#	1	3	~	5-	32590
------	---	---	---	----	-------

Permit # 27760

Harnett County Department of Public Health Site Sketch

