

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address:
 Proposed Facility: 3800m Date Evaluated:
 Location of Site: Design Flow (.1949): 360 gpd Property Size:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L5 0-2	0-17	G SL	VFA NS/MP					
		17-28	SBK CL	FR SS/SP					
		28-48	SBK C	FR S/P					P5 .3
2		0-11	G SL	VFA NS/MP					
		12-42	SBK SL	FR SS/SP					P5 .3
		42-60	SBK C	FR S/P	10YR 7/2 2.5				
3		0-18	G SL	VFA NS/MP					
		18-32	SBK CL	FR SS/SP					
		32-40	SBK C	FR S/P					P5 .3

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): OS Evaluated By: [Signature] Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	28% R60		
Site LTAR	3	3	

5x60