

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: William & Dorothy McLamb

Address: 1092 Mcarton Rd

Date: 8-18-14

Building Official: James T. Hall

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: 14-500-33651

ADDRESS : 1092 MCARTAN RD SUBDIV:
 CONTRACTOR : TITAN DESIGNS MANAGEMENT PHONE : (910) 258-1348
 OWNER : MCLAMB WILLIAM R & DOROTHY PHONE :
 PARCEL : 01-0544- - -0014- -01-
 APPL NUMBER: 14-50033651 CP MANUFACTURED HOME RA20R/RA20M CRITERIA

DIRECTIONS : T/S: 05/14/2014 03:07 PM DJOHNSON --
 210S ABOUT 7-8 MILES TO FLAT BRANCH
 FIRE DEPARTMENT TAKE ELLIOTT BRIDGE RD
 ABOUT 5 MILES THEN LEFT ONTO MCARTAN RD
 1.25 MILE ON RIGHT

STRUCTURE: 000 000 32X76 4 BR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : DWMH
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H824 01	7/14/14	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002554947
	7/14/14	AP	T/S: 07/15/2014 11:32 AM SSTEWARD ----- T/S: 07/15/2014 11:33 AM SSTEWARD -----
T501 01	7/14/14	JH	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002553733
	7/14/14	DA	T/S: 07/11/2014 12:23 PM VBROWN ----- T/S: 07/11/2014 12:24 PM VBROWN ----- problems call the preacher up the rd at 910 890 4357 or 893 9181 overhills church. 1)Need engineer letter for fill soil added on right side of home.2)Need to install sewer line & DWV test.3)Need cross over duct installed for heat.4)Ridge cap needs to be installed.5) 6 mil poly lapped 6" per code needs to be installed under house.
T501 02	7/23/14	JH	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002557569
	7/23/14	AP	T/S: 07/22/2014 09:38 AM VBROWN -----
A814 01	7/24/14	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002558302
	7/24/14	AP	T/S: 07/23/2014 02:33 PM LSEGARS ----- 1092 MCARTAN RD LINDEN 28356 T/S: 07/24/2014 11:10 AM TWARD -----
Z818 01	7/28/14	RB	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002558310
	7/28/14	AP	T/S: 07/23/2014 02:34 PM LSEGARS ----- T/S: 07/28/2014 10:32 AM RBAKER -----
T507 01	8/18/14	TI	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002568681
	8-18-14	AP IV	T/S: 08/15/2014 03:17 PM DJOHNSON -----

COMMENTS AND NOTES