

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: MELISSA A STEPHANSON
PROPERTY LOCATION: 581441 Chalybeate Springs RD
SUBDIVISION:
LOT #:
NEW [X] REPAIR [] EXPANSION []
Type of Structure: DWMH
Proposed Wastewater System Type: 25% REDUCTION
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement [] Yes [X] No
Pump Required: [] Yes [] No [X] May be required based on final location and elevations of facilities
Type of Water Supply: [] Community [X] Public [] Well
Distance from well: feet
Permit valid for: [X] Five years [] No expiration
Permit conditions: CONTRACTOR TO MEET ON SITE PRIOR TO COME

Authorized State Agent: James E. Markland Date: 7-17-14 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: MELISSA A STEPHANSON
PROPERTY LOCATION: 581441 Chalybeate Springs RD
SUBDIVISION:
LOT #:
Facility Type: DWMH [X] New [] Expansion [] Repair
Basement? [] Yes [X] No Basement Fixtures? [] Yes [X] No
Type of Wastewater System: 25% REDUCTION System (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable [])
Pump to 25% REDUCTION (Repair)
Installation Requirements/Conditions
Number of trenches: 2
Septic Tank Size: 1000 gallons Exact length of each trench: 150 feet Trench Spacing: 9 Feet on Center
Pump Tank Size: gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: ft. TDH vs. GPM Aggregate Depth: 6 inches below pipe, 2 inches above pipe
Conditions: CONTRACTOR TO MEET ON SITE PRIOR TO COME 12 inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markland Date: 7-17-14
Construction Authorization Expiration Date: 7-17-19

HTE# 14-5-34095

Permit # 27893

Harnett County Department of Public Health Site Sketch

ISSUED TO: Melissa A STEPHANSON PROPERTY LOCATOR: SR 1441 Chalybeate Springs RD SUBDIVISION _____ LOT # _____

Authorized State Agent: James S Manhart ^{DEP REGS.} Date: 7-17-14

* RUN WATER AND POWER TO DRIVEWAY AREAS

* Contractor to meet on site prior to install. (* Pets to check for depth)

