


**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: \_\_\_\_\_ Applicant: \_\_\_\_\_  
 Address: \_\_\_\_\_ Date Evaluated: \_\_\_\_\_  
 Proposed Facility: *W/W* Design Flow (.1949): *300* Property Size: \_\_\_\_\_  
 Location of Site: *Fedco* Property Recorded: \_\_\_\_\_  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L <sup>20</sup>	0-18	SL	FR GRAN SP					
		18-40	SC-clay	FR 10% SP	38-45 0.5 3.1				4
2	-20	0-20	SL	FR GRAN SP					
		20-42	SC-clay	FR 10% SP	10-42 7.5 5+				4
3	L <sup>22</sup>	0-18	SL	FR GRAN SP					
		18-42	SC-clay	FR 10% SP	38-40 7.5 5+				4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By:  Others Present:
Available Space (.1945)			
System Type(s)	250	200	
Site LTAR	4	4	