

COUNTY OF HARNETT  
Building Inspections Department  
Planning Services

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Manufactured Home

Name: Espinoza Humbertina

Address: 13897 McJougald Rd

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Date: 4/29/15

Building Official: \_\_\_\_\_

[Signature]

**Permit Numbers**

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

50034706

INSPECTION TICKET  
INSPECTOR: IVR

7/15, 14:34:22  
ty

SUBDIV: NOELL HILLS PHASE III  
PHONE : (910) 690-9222  
PHONE :

TRACTOR : 13897 MCDOUGALD RD  
: A PLUS CONSTRUCTION  
NER : ESPINOZA HUBERTINA  
PARCEL : 03-9569- -0003- -23-  
APPL NUMBER: 14-50034306 CP MANUFACTURED HOME RA20R/RA20M CRITERIA  
DIRECTIONS : T/S: 07/30/2014 11:40 AM VBROWN ----  
13897 MCDOUGALD RD SANFORD 27332. 500  
FT FROM COOPER STORE RD OFF OF  
MCDOUGALD.

STRUCTURE: 000 000 24X60 3BDR DWMH  
FLOOD ZONE : FLOOD ZONE X 3.00  
# BEDROOMS :  
PROPOSED USE : DWMH  
WATER SUPPLY : COUNTY

MOBILE HOME YEAR : 2002.00  
SEPTIC - EXISTING? : EXIST

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	TIME	VRU #
T501 01	9/10/14	FS	R*MOBILE HOME FOUND./ M. WALL	17:00	002576148
	9/10/14	AP	T/S: 09/10/2014 02:51 PM FSPIVEY		
A814 01	9/12/14	TW	ADDRESS CONFIRMATION	17:00	002577781
	9/12/14	AP	13897 MCDOUGALD RD SANFORD 27332		
Z818 01	9/30/14	RB	T/S: 09/12/2014 10:07 AM TWARD	17:00	002583607
	9/30/14	AP	PZ*ZONING INSPECTION		
T507 01	2/16/15	TSG	R*MANUFACTURED HOME FINAL	17:00	002627511
	2/16/15	DA	1 rear steps nott installed fully against house leaving gap		
			2-Duct work has holes torn in it that need repair		
T507 02	4/29/15	TR	R*MANUFACTURED HOME FINAL	17:00	002652345
			T/S: 04/27/2015 03:37 PM LBENNETT		
			T/S: 04/27/2015 03:38 PM LBENNETT		

*[Handwritten signatures]*

COMMENTS AND NOTES