

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: Date Evaluated:
 Address: Design Flow (.1949): 360 gpd Property Size:
 Proposed Facility: 3000m Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941		.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy					
1	LS 2.5	0-14	GS	YFf ss/SP					
		12-40	SBK SCL	F2 SS/SP					PS .4
2		0-16	GS	YFf ss/SP					
		16-24	SBK SCL	F2 SS/SP					PS .4

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946): PS
Available Space (.1945)			Site Classification (.1948): OY
System Type(s)	2 S ¹ / ₁ , 2 S ² / ₁	2 S ² / ₁	Evaluated By: OY
Site LTAR	12	12	Others Present: -