

1550035279

LW A PE

Larry W. Anderson, P.E.
Consulting Engineer
P.O. Box 1736
Lumberton, NC 28359

(910) 671-9530
(910) 608-2808

January 28, 2015

Mr. Gregory Hicks
1494 Rainey Drive
Spring Lake, NC 28390

Ref.: Over-Height Set Up
Manufactured Home

Mr. Hicks,

Based upon my site visit and inspection of the above referenced home, I am of the opinion that with the addition of cross bracing and pier surface reinforcing, the unit will resist any anticipated loads based upon the current ASCE 7-10 standards for wind loads.

Should you have any questions, please do not hesitate to contact me.

Sincerely,



Larry W. Anderson, P.E.

LWA/jeg

