

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: *1/30/245*
 Proposed Facility: Design Flow (.1949): Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	<i>5690</i>	<i>0-48</i>	<i>G/LS</i>	<i>Vfr NS NP</i>					<i>5.8</i>
		<i>0-24</i>	<i>G/LS</i>	<i>Vfr NS NP</i>					
		<i>24-42</i>	<i>SBK/SC1</i>	<i>Fr SS SP</i>					<i>PS.4</i>
		<i>42</i>	<i>AR</i>						
		<i>0-18</i>	<i>cl LS</i>	<i>Vfr NS NP</i>					
		<i>18-36</i>	<i>SBK/SC1</i>	<i>Fr SS SP</i>					<i>PS.6</i>
		<i>36-48</i>	<i>cl LS</i>	<i>Vfr NS NP</i>					
		<i>0-22</i>	<i>G/LS</i>	<i>Vfr NS NP</i>					
		<i>22-34</i>	<i>SBK/SC1</i>	<i>Fr SS SP</i>					<i>PS.4</i>
		<i>34-42</i>	<i>G/LS</i>	<i>Vfr NS NP</i>					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>DM</i> Others Present:
Available Space (.1945)			
System Type(s)	<i>25E</i>	<i>25E</i>	
Site LTAR	<i>.6</i>	<i>.7</i>	