
ADDRESS . : 909 MIKE WILLIAMS LN SUBDIV: NANCY GODWIN ESTATE
CONTRACTOR : A PLUS CONSTRUCTION PHONE : (910) 690-9222
OWNER . . : WILLIAMS MICHAEL E PHONE :
PARCEL . . : 01-0545- - -0073- -01-
APPL NUMBER: 15-50035661 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : T/S: 03/11/2015 09:38 AM VBROWN ----
ON THE SAME PARCEL AS 875 MIKE WILLIAMS
LANE, PURPOSED DWMH IS ON SAME PARCEL
AS 875 MIKE WILLIAMS LANE OFF OF NC
210S

STRUCTURE: 000 000 31X76 4BDR DWMH

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 MOBILE HOME YEAR : 2015.00
PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW TANK
WATER SUPPLY : NEW WELL

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	4/27/15 4/28/15	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002651842 909 Mike Williams Ln Bunnlevel 28323 T/S: 04/28/2015 09:34 AM TWARD -----
T501 01	5/06/15 5/06/15	JH DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002655306 1)Need engineer letter for over height home per code.2)House locked no key in meter base.3)Ground the two halves together.
H824 01	5/07/15 5/07/15	BM DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002656668 ON HOLD FOR WELL INSTALLATION.CALL WHEN READY TO INSTALL WELL AND THEN OPERATIONS PERMIT FOR SEPTIC CAN BE ISSUED.BRYAN MCSWAIN 893-7547. T/S: 05/07/2015 08:28 AM SSTEWARD -----
T501 02	5/11/15 5/11/15	JH DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002657260 T/S: 05/08/2015 01:03 PM KGOINS ----- Still waiting on engineers letter for over height home----
T501 03	5/27/15 5/27/15	JH AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002663920 -----
H824 02	5/28/15 5/28/15	BM AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002665347 T/S: 05/28/2015 11:40 AM SSTEWARD ----- T/S: 05/28/2015 11:40 AM SSTEWARD -----
Z818 01	5/28/15 5/28/15	RB AP	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002665552
T507 01	5/29/15	TI	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002665750

5-29-15 APJH

----- COMMENTS AND NOTES -----

✓

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Michael Williams

Address: 909 Mike Williams Ln

Date: 5-29-15

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: 15-30035661

Building Official: _____

James J. Hall