Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 4/20/15
Proposed Facility: Design Flow (.1949): Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	[illegible]	0-30	G/LS	Vfr NSP					
		30-36	SBK/C	Fi SSSP	10YR 5/6 @ 32"				PS.4
		0-30	G/LS	Vfr NSP					
		30-42	SBK/C	Fi SSSP	10YR 7/1 @ 42"				PS4
		0-27	G/SL	Vfr NSP					
		27-43	SBK/SCL	Fi SSSP					PS.4

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	Pump Trench	2 SS.
Site LTAR	.4	.4

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: [illegible]
Others Present: