

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Joseph Miller

Address: 2725 Byrds Mill Rd

Date: 12-30-16

Building Official:

James Hall

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: 15-S9037321

ADDRESS : 2725 BYRDS MILL RD
CONTRACTOR : CHOO'S MOBILE HOME TRANSIT
OWNER : MILLER JOSEPH R
PARCEL : 12-0576- - -0022- -18-
APPL NUMBER: 15-50037321 CP MANUFACTURED HOME RA20R/RA20M CRITERIA

DIRECTIONS : T/S: 10/19/2015 11:42 AM JBROCK ----
2725 BYRDS MILL RD
T/S: 12/29/2016 08:16 AM DJOHNSON --
***** PLEASE GIVE BACK TO TECH AT
FINAL. SWMH TO BE REMOVED AFTER 5 DAYS
OF FINAL*****

LAND NOTES : LXMN 4/22/04 GODWIN & JOHNSON TR#3

STRUCTURE: 000 000 28X52 3BDR DWMH

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 MOBILE HOME YEAR : 21012.00
PROPOSED USE : DWMH SEPTIC - EXISTING? : EXT TANK
WATER SUPPLY : COUNTYN

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	12/05/16 12/05/16	JH DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002906162 T/S: 12/02/2016 12:48 PM LBENNETT ----- 1)House locked 2)No plumbing installed under house drain lines or water lines with test per code.3100 percent 6 mil poly lapped 12" and pinned in place.
T501 02	12/07/16 12/07/16	JH DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002907475 T/S: 12/06/2016 10:31 AM LBENNETT ----- not ready
T501 03	12/09/16 12/09/16	JH AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002908374 T/S: 12/08/2016 10:49 AM JFORBES -----
A814 01	12/22/16 12/22/16	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002913614 2725 BYRDS MILL RD ERWIN 28339 T/S: 12/22/2016 09:55 AM SBENNETT -----
Z818 01	12/22/16 12/22/16	RB DA	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002913606 T/S: 12/21/2016 11:26 AM JBROCK ----- T/S: 12/22/2016 10:27 AM JBROCK ----- SWMH IS STILL ON SITE
Z818 02	12/29/16 12/29/16	RB AP	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002914984 T/S: 12/29/2016 01:57 PM LBENNETT -----
T507 01	12/30/16	TL	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002915510 T/S: 12/29/2016 01:58 PM LBENNETT -----

12-30-16 APJ

Reverse # 46870287

COMMENTS AND NOTES