

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3 BORM Design Flow (.1949): 360 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
			RGPA 12 R2BA TYPICAL						
1	LS 0-2	0-6	GS	VFA NS/VP					
		0-22	SBK SL	F1 S/SP	10YR7/2 e22"				PS .3 A22 .1
			INITIAL R2BA TYPICAL						
	LS 0-2	0-10	GS	VFA NS/VP					
		10-26	SBK SL	FRS/SP	10YR7/2 e25"				PS .4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>B</u> Evaluated By: <u>OT [Signature]</u> Others Present: <u>JM/AC</u>
Available Space (.1945)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
System Type(s)	<u>PS</u>	<u>PS</u>	
Site LTAR	<u>1</u>	<u>1</u>	