

ADDRESS : 25 JIMMY DR SUBDIV: AUTRY ACRES
CONTRACTOR : MOBILE SERVICES PHONE : (910) 291-0248
OWNER : PURCELL NINA PHONE :
PARCEL : 12-0556- - -0140- - -
APPL NUMBER: 16-50040465 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : T/S: 12/29/2016 08:56 AM DJOHNSON --
401 S TO BUNNLEVEL MCLEAN CHAPEL CHURCH
RD TURN RIGHT AND GO TO WIRE RD. TURN
LEFT AND GO DOWN TO JIMMY DR THEN RIGHT
FIRST MOBILE HOME ON LEFT
T/S: 03/21/2017 12:58 PM DJOHNSON --
****PREMISE NO 97314829****
LAND NOTES : LXMN 1/27/03 AUTRY ACRES S/D LOT#1

STRUCTURE: 000 000 28X68 4 BR NO DECKS/PORCHES

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 MOBILE HOME YEAR : 2016.00
PROPOSED USE : DWMH SEPTIC - EXISTING? : EXISTING
WATER SUPPLY : COUNTY

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H824 01	3/03/17	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002941201
	3/03/17	AP	T/S: 03/06/2017 10:20 AM KHINSON ----- T/S: 03/06/2017 10:20 AM KHINSON -----
T501 01	3/10/17	JH	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002943132
	3/10/17	DA	Tape damaged bottom board where lag bolts are installed under house per setup manual.
T501 02	3/15/17	JH	R*MOBILE HOME FOUND./ M. WALL VRU #: 002944924
	3/15/17	DA	1)Need cutoff and prv at water connection from house.2)Insulate water line with R6.5 per code 3)Tape all damaged bottom boards where lag bolts went through & cover cross connections under house.4)Need 6 mil poly under house per code.
T501 03	3/16/17	JH	R*MOBILE HOME FOUND./ M. WALL VRU #: 002945718
	3/16/17	DP	NOTHING FIXED FROM YESTERDAY \$50.00 FEE & THE CONTRACTOR STILL OWE THE SECIAL INSPECTION FEE FOR THE MARR WALL ONLY THAT HAS STILL NOT PASSED, IS A \$50.00 FEE
T501 04	3/21/17	JH	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002947125
	3/21/17	AP	T/S: 03/20/2017 01:23 PM JBROCK -----
Z818 01	3/23/17	AD	PZ*ZONING INSPECTION VRU #: 002948163
	3/23/17	DA	MUST HAVE AP & PERMITS FOR THE TRAVEL TRAILER, OR IT WILL NEED TO BE DISCONNECT FROM ALL SERVICES & PARKED & STORED FOR REC PROPOSES ONLY
A814 01	3/24/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002948902
	3/24/17	AP	25 JIMMY DR BUNNLEVEL 28323 T/S: 03/24/2017 12:04 PM SBENNETT -----
Z820 01	3/27/17	TI	PZ*ZONING/FINAL INSPECTION VRU #: 002949732

3/27/17 AP/AD

deleted zoning out of this permit.

PERMIT: CPLU 00 CP LAND USE PERMIT

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS