

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Manufactured

Name: Martin Beathe

Address: 125 Clemons

Date: 3/21/18

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: 50040969

Building Official: [Signature]

ADDRESS . . : 125 CLEMONS LN
CONTRACTOR :
OWNER . . : MARTIN BEATHE (WILLIAMS)
PARCEL . . : 09-9568- - -0053- - -
APPL NUMBER: 17-50040969 CP MANUFACTURED HOME RA20R/RA20M CRITERIA
DIRECTIONS : T/S: 03/21/2017 08:06 AM DJOHNSON --
24/27 THEN RIGHT ON BBQ CHURCH RD. THEN
LEFT ONTO OLIVIA RD RIGHT ON MURCHINSON
TOWN RD

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 14X70 3 BR NO DECKS/PORCHES

FLOOD ZONE : FLOOD ZONE X
BATHS : 2
MOBILE HOME YEAR : 1986.00
SEPTIC - EXISTING? : EXISTING
BEDROOMS : 2.00
PROPOSED USE : SWMH
WATER SUPPLY : EXISTING WELL

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	3/09/18 3/09/18	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003099900 125 CLEMONS LN SANFORD 27332 T/S: 03/09/2018 09:31 AM SBENNETT -----
T501 01	3/09/18 3/09/18	TSG AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 003099728 T/S: 03/08/2018 11:18 AM BPETRICH -----
Z818 01	3/16/18 3/16/18	AD AP	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 003102225 T/S: 03/15/2018 12:01 PM JBROCK -----
T507 01	3/20/18 3/20/18	TSG DA	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 003103462 T/S: 03/19/2018 01:52 PM LLUCAS ----- 1-SMOKE DETEDTORS REQUIRED / BEDROOMS 2-ADD DIRT AT FRONT STEPS FIRST STEPP OVER 8 1/4 . 3-ADD MEMBER TO FRONT STEPS AT BOTTOM OF RAILS/STEPS 4-SEWER CLEAN OUT REQUIERED BETWEEN BUILDING AND TANK
T507 02	3/21/18	TI	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 003103926 T/S: 03/20/2018 11:55 AM BPETRICH -----

[Handwritten signatures]

COMMENTS AND NOTES