HTE# 17-5-41256

Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: MERCEDES SUBDIVISION WESHOOD 4 EXPANSION 📮 Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Man Hame (14×70' Proposed Wastewater System Type: CONVENTIONAL Projected Daily Flow: Number of bedrooms: Number of Occupants: Basement Yes Pump Required: Tes No ☐ May be required based on final location and elevations of facilities Type of Water Supply:
Community Public Well Distance from well feet Permit valid for: Five years Permit conditions: ☐ No expiration SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1954, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance ISSUED TO: ROSCOTO POOR PROPERTY LOCATION: MERCEDGS LN SUBDIVISION Washad 4 ☐ Expansion ☐ Repair Basement? Yes Basement Fixtures?

Yes (Initial) Wastewater Flow: 360 Type of Wastewater System** CONTENTIONAL **GPD** (See note below, if applicable

) LAND TUSINO Installation Requirements/Conditions Number of trenches Exact length of each trench 150 Trench Spacing: Septic Tank Size 1000 gallons Feet on Center Pump Tank Size gallons Trenches shall be installed on contour at a Soil Cover: 6-24 Maximum Trench Depth of: 18-36 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. inches below pipe Aggregate Depth: ______ inches above pipe Conditions: inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the previsions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Construction Authorization Expiration Date:

Harnett County Department of Public Health Site Sketch

Authorized State Agent:

PROPERTY LOCATON: MEDICEDES LM

SUBDIVISION WESHOOD 5

Date: 5/0/17

