

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Manufactured  
Name: \_\_\_\_\_

Address: 820 Cypress Church Rd  
\_\_\_\_\_  
\_\_\_\_\_

Date: 2/13/18

Building Official: [Signature]

**Permit Numbers**

Building: \_\_\_\_\_  
Electrical: \_\_\_\_\_  
Insulation: \_\_\_\_\_  
Plumbing: \_\_\_\_\_  
Mechanical: \_\_\_\_\_  
MFG Home: 50041470

ADDRESS : 820 CYPRESS CHURCH RD SUBDIV:  
CONTRACTOR : RAVEN ROCK MOBILE HOME MOVER PHONE : (919) 775-3600  
OWNER : BANDY ISIENORA PHONE :  
PARCEL : 09-9554- - -0033- -02-  
APPL NUMBER: 17-50041470 CP MANUFACTURED HOME RA20R/RA20M CRITERIA  
DIRECTIONS : T/S: 05/24/2017 11:52 AM BPETRICH --  
820 CYPRESS CHURCH ROAD CAMERON 28326

STRUCTURE: 000 000 32X56 3BDRM DWMH

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 MOBILE HOME YEAR : 2000.00  
PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW  
WATER SUPPLY : COUNTY

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	1/09/18 1/09/18	TSG DA	R*MOBILE HOME FOUND./ M. WALL VRU #: 003073400 1-PROTECT/ SUPPORT ELECTRICAL CROSS OVER UNDER HOME 2-ALL WORK UNDER HOME IS TO BE COMPLETED AT THIS TIME, ELECTRICAL, PLUMBING, MECANICAL ECT BEFORE SKIRT IS INSTALLED.
A814 01	1/09/18 1/08/18	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003073418 820 CYPRESS CHURCH RD CAMERON 28326 T/S: 01/08/2018 09:14 AM SBENNETT -----
T501 02	1/24/18 1/24/18	TSG DP	R*MOBILE HOME FOUND./ M. WALL VRU #: 003078854 1- electrical cross over item from last inspection not corrected. 2-electrical romex on ground unprotected. 3-a/c drain back falling installed with belly.
T501 03	2/02/18 2/02/18	TSG AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 003084340 T/S: 02/01/2018 11:21 AM JBROCK -----
H824 01	2/06/18 2/06/18	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003086485 T/S: 02/07/2018 09:29 AM KHINSON ----- T/S: 02/07/2018 09:29 AM KHINSON -----
Z818 01	2/08/18 2/08/18	AD DP	PZ*ZONING INSPECTION VRU #: 003086675 T/S: 02/08/2018 09:35 AM BPETRICH ----- PER AMY DRIGGERS - NOT READY FOR INSPECTION
Z818 02	2/09/18 2/09/18	AD AP	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 003087210 T/S: 02/08/2018 09:56 AM JBROCK ----- T/S: 02/09/2018 11:07 AM ADRIGGER -----
T507 01	2/13/18		R*MANUFACTURED HOME FINAL VRU #: 003088077

COMMENTS AND NOTES