

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Manufactured  
Name: Spiegel Barry M + Linda

Address: 484 DR HARVELL LANE

Date: 1/12/18

Building Official: S. GUY

**Permit Numbers**

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: 50042526

ADDRESS : 484 D R HARVELL LN SUBDIV: JOEL LAYTON ESTATE  
CONTRACTOR : A PLUS CONTRACTOR PHONE : (910) 690-9222  
OWNER : SPIEGEL BARRY M & LINDA PHONE :  
PARCEL : 10-0549- - -0031- -08-  
APPL NUMBER: 17-50042526 CP MANUFACTURED HOME RA20R/RA20M CRITERIA  
DIRECTIONS : T/S: 10/10/2017 02:01 PM BPETRICH --  
LILLINGTON TO HWY 27 W - IN 2 MILES  
TURN RIGHT ON D R HARVELL LANE - LOT IS  
AT THE VERY END OF THE ROAD ON THE  
RIGHT HAND SIDE.  
PREMISE#39478417  
T/S: 12/19/2017 10:35 AM LLUCAS ----

**STRUCTURE: 000 000 32X64 3BD 2BA DWMH**

FLOOD ZONE : FLOOD ZONE X  
# BATHS : 2 # BEDROOMS : 3.00  
MOBILE HOME YEAR : 2018.00 PROPOSED USE : DWMH  
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : EXISTING WELL

**PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	11/28/17 11/28/17	KS AP	R*MOBILE HOME FOUND./ M. WALL VRU #: 003057863 T/S: 11/28/2017 12:46 PM KSLATTUM ----- Left note to bond frames together.
A814 01	11/29/17 11/29/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003058971 484 D R HARVELL LN LILLINGTON 27546 T/S: 11/29/2017 09:21 AM SBENNETT -----
H824 01	12/11/17 12/11/17	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003066370 T/S: 12/13/2017 10:54 AM KHINSON ----- T/S: 12/13/2017 10:54 AM KHINSON -----
Z818 01	12/28/17 12/28/17	RB AP	PZ*ZONING INSPECTION VRU #: 003070508 T/S: 12/28/2017 10:26 AM RBAKER -----
T507 01	1/01/18 1/02/18	TSG DA	R*MANUFACTURED HOME FINAL VRU #: 003071927 1- grade at front of home must slope away from home, water is not allowed to run under home. 2-locate two ground rods 3-sewer clean out required outside of home.
T507 02	1/12/18	TI	R*MANUFACTURED HOME FINAL VRU #: 003075200

*Handwritten signature: J. C. AP*

COMMENTS AND NOTES

*Handwritten number: 39478417*

HARNETT COUNTY CENTRAL PERMITTING

P.O. BOX 65

LILLINGTON, NC 27546

For Inspections Call: (910) 893-7525 Fax: (910) 893-2793


Bldg Insp scheduled before 2pm available next business day.

-----

Application Number . . . . . 17-50042526 Date 11/07/17  
 Property Address . . . . . 80478 \*UNASSIGNED  
 PARCEL NUMBER . . . . . 10-0549- - -0031- -08-  
 Application type description CP MANUFACTURED HOME RA20R/RA20M CRITERI  
 Subdivision Name . . . . . JOEL LAYTON ESTATE  
 Property Zoning . . . . . PENDING

Owner  
 -----  
 SPIEGEL BARRY M & LINDA  
 PO BOX 2598  
 LILLINGTON NC 27546

Contractor  
 -----  
 A PLUS CONTRACTOR  
 5369 US HWY I N  
 VASS NC 28394  
 (910) 690-9222



Applicant  
 -----  
 SPIEGEL BARRY

--- Structure Information 000 000 32X64 3BD 2BA DWMH  
 Flood Zone . . . . . FLOOD ZONE X  
 Other struct info . . . . . # BATHS 2  
 # BEDROOMS 3.00  
 MOBILE HOME YEAR 2018.00  
 PROPOSED USE DWMH  
 SEPTIC - EXISTING? NEW TANK  
 WATER SUPPLY EXISTING WELL

-----  
 Permit . . . . . MANUFACTURED HOME PERMIT  
 Additional desc . . . . .  
 Phone Access Code . . . . . 1217587  
 Issue Date . . . . . 11/07/17 Valuation . . . . . 0  
 Expiration Date . . . . . 11/07/18

-----  
 Permit . . . . . LAND USE PERMIT  
 Additional desc . . . . .  
 Phone Access Code . . . . . 1217553  
 Issue Date . . . . . 11/07/17 Valuation . . . . . 0  
 Expiration Date . . . . . 5/06/18

-----  
 Special Notes and Comments  
 T/S: 10/10/2017 02:01 PM BPETRICH --  
 LILLINGTON TO HWY 27 W - IN 2 MILES  
 TURN RIGHT ON D R HARVELL LANE - LOT IS  
 AT THE VERY END OF THE ROAD ON THE  
 RIGHT HAND SIDE.

-----

HARNETT COUNTY CENTRAL PERMITTING

P.O. BOX 65

LILLINGTON, NC 27546

For Inspections Call: (910) 893-7525 Fax: (910) 893-2793

Bldg Insp scheduled before 2pm available next business day.

Application Number . . . . .	17-50042526	Page	2
Property Address . . . . .	80478 *UNASSIGNED	Date	11/07/17
PARCEL NUMBER . . . . .	10-0549- - -0031- -08-		
Application description . . . . .	CP MANUFACTURED HOME RA20R/RA20M CRITERI		
Subdivision Name . . . . .	JOEL LAYTON ESTATE		
Property Zoning . . . . .	PENDING		

Required Inspections

Seq	Phone Insp#	Insp Code	Description	Initials	Date
Permit type . . . . . MANUFACTURED HOME PERMIT					
10	501	T501	R*MOBILE HOME FOUND./ M. WALL	_____	___/___/___
10	814	A814	ADDRESS CONFIRMATION	_____	___/___/___
20	818	Z818	PZ*ZONING INSPECTION	_____	___/___/___
30	507	T507	R*MANUFACTURED HOME FINAL	_____	___/___/___
999		H824	ENVIR. OPERATIONS PERMIT	_____	___/___/___
999	307	P307	R*PLUMB WATER CONNECTION	_____	___/___/___